Advanced Metering Infrastructure

October 20, 2021

H Warren Field Division Manager



AMI (Advanced Metering Infrastructure)

• **AMI** –refers to the equipment used to collect, store and forward information from the meter to the meter database management system(MDM).





Water Authority's Advanced Metering Infrastructure

- 9 Base Stations
- 120,000 accounts
 - 61%
- Current Install rate
 - ~22,000 annually



Why AMI?

AMI Accounts

- Hours to process/read 120,000: 6 hours
 - Cost sunk cost of meter and endpoint
 - Reduced carbon footprint
- Reduced exposure and injury
- Read Accuracy
 - 99.97%
- Large Meters
 - 30% of Revenue
 - Fast response to meter failure

Non-AMI Accounts

- Hours to process/read 80,000: 1500 hours
 - Cost per month \$31,500
 - ~400 miles driven per day for meter crew
- Read Accuracy
 - 98%

- Residential leak detection
- Pressure Monitoring
- Sewer applications
 - Vacuum stations
 - Odor control
 - SSO detection
- Large Meters
 - 30% of Revenue
 - Fast response to meter failure





- Large Meter Testing
 - ~1000 large meters
 - Top 25 users tested annually
 - All others every 2 years
- Each unbilled unit has a compounding effect for not only water but wastewater

CLASS AVERAGE AMOUNTS FOR APRIL 2018 Thru MARCH 2019											
SIZE		RESID		сомм		INDUST		INSTIT		MUL FAM	
1		6		8		21		8		12	
2		8		19		57		14		24	
3		11		43		153		26		85	
4		44		97		526		51		175	
5		240		239		1,429		152		585	
6		626		460		1245		474		884	
7		1741		806		5046		489		1064	
8		1136		894		1869		1137		1088	
BLUE decrease GREENno change			YELLOW increase		PINKno service this size in class						

CLASS AVERAGE AMOUNTS FOR APRIL 2017 Thru MARCH 2018

SIZE	RESIDENTIAL COMMERCIAL			AL	INDUSTRIAL		INSTITUTIONAL MUL FAM			
1	6		8		12		8		12	
2	7		19		55		16		24	
3	8		42		163		28		88	
4	56		100		190		49		179	
5	240		289		613		109		564	
6	626		498		1017		318		880	
7	1741		613		3271		503		924	
8	1136		872		1869		855		1052	



- Pressure Monitoring
- Pressure Sustaining Valve (PSV) got stuck open by debris, causing it to not be able to close
- This in turn caused pressure to bleed from zone
- 20 PSI detected at customer location



- PSV indicated a potential redundancy issue in the system, when the Alameda trunk was supplied by Palomas/Holbrook PRV
- This in turn led to Water Authority crews extending a 6" main
- Provided additional flexibility to move water across trunks



Questions

TUTHOP'